



- ① REMOVE (E) FIRE SPRINKLER WATERFLOW SWITCH FOR BUILDING 45.
- ② REMOVE (E) FIRE SPRINKLER WATERFLOW SWITCH AND VALVE POSITION SUPERVISORY SWITCH FOR BUILDING 43. RETAIN THE WATERFLOW SWITCH AND VALVE SUPERVISORY SWITCH FOR REINSTALLATION AT A NEW LOCATION.
- ③ REMOVE (E) MANUAL FIRE ALARM CALL BOX ON THE EXTERIOR OF BUILDING 45. RETAIN THE MANUAL FIRE ALARM CALL BOX AT A NEW LOCATION.
- ④ REMOVE (E) FIRE ALARM CONDUIT AND CIRCUITS ROUTED THROUGH AND ATTACHED TO BUILDING 45. RETAIN THE FIRE ALARM CIRCUITS FOR REINSTALLATION AT A NEW LOCATION.



- ① INSTALL TEMPORARY RACEWAY UTILIZING THE EXISTING CIRCUITS REMOVED IN KEY NOTE #4, DETAIL 1 TO SERVE THE FIRE SPRINKLER WATERFLOW SWITCH, VALVE POSITION SUPERVISORY SWITCH AND MANUAL FIRE ALARM CALL BOXES FOR BUILDING 63. INSTALL RACEWAY ALONG THE EXISTING TRENCH NORTH OF BUILDING 45.
- ② INSTALL TEMPORARY FIRE SPRINKLER WATERFLOW SWITCH AND VALVE POSITION SUPERVISORY SWITCH FOR BUILDING 43 UTILIZING THE WATERFLOW SWITCH AND VALVE SUPERVISORY SWITCH REMOVED IN KEY NOTE #2, DETAIL 1.
- ③ INSTALL MANUAL FIRE ALARM CALL BOX ON THE EXTERIOR OF BUILDING 45 UTILIZING THE MANUAL FIRE ALARM CALL BOX REMOVED IN KEY NOTE #3, DETAIL 1.
- ④ REMOVE (E) FIRE ALARM CONDUIT AND CIRCUITS ROUTED THROUGH AND ATTACHED TO BUILDING 45. RETAIN THE FIRE ALARM CIRCUITS FOR REINSTALLATION AT A NEW LOCATION.



1629 Telegraph Avenue
Suite 200
Oakland, CA 94612
Tel 510 272 0654
Fax 510 444 0279



ISSUE	(PROGRESS, ESTIMATE, BID, CONSTRUCTION CONFORMED, REVISION, AS-BUILT)
-------	--

C	HYT	HYT		12.02.11	100% CONSTRUCTION DOCUMENTS REVIEW COMMENT	
B	HYT	HYT		11.10.11	100% CONSTRUCTION DOCUMENTS	
A	HYT	HYT		09.30.11	75% CONSTRUCTION DOCUMENTS	
REVISION NUMBER	DRAWN BY	CHECKED BY	APPR'D BY	DATE	REMARKS	

FACILITIES DIVISION

DRAWN BY		HYT	DATE	12.02.11
CHECKED BY		HYT	12.02.11	
APPROVED BY				
CAD FILE PATH				
SCALE AS NOTED				
DRAWING NO.			SHEET	
4B45E026			FA1.0	
PROJECT NO.			38 OF 43	